Apparatus Licence

Issued by Delegate of the Australian Communications and Media Authority

Licensee details

Customer ID	20004872
Licensee	DEPT OF HEALTH QLD
Trading name	eHealth Qld
Licensee address	GPO Box 125 RBWH, BRISBANE, QLD 4001

Licence details

Licence service	Land Mobile
Licence subservice	Paging System - Exterior
Licence number	1988402/1
Date of issue	12/04/2023
Date of effect	12/04/2023
Date of expiry	30/04/2024

Licence conditions

Your licence is subject to conditions set out in the *Radiocommunications Act 1992*. Your licence may also be subject to such other licence conditions as determined by the ACMA (in licence condition determinations) from time to time, and is also subject to special conditions as detailed on this licence.

The conditions that are imposed on a licence vary according to the type of licence issued, the service being operated and the section of the *Radiocommunications Act 1992* under which the licence has been issued. For further information about the conditions that apply to your licence, please contact the ACMA (see contact details below).

Rights of appeal

A decision by the ACMA to impose further conditions or revoke or vary the conditions of your licence may be reviewable. If you are affected by, and dissatisfied with, such a decision you may apply to the ACMA to have the ACMA reconsider the decision under section 288 of the *Radiocommunications Act 1992*.

An application for reconsideration must state the reasons for the request, and should be sent to the Customer Service Centre, Australian Communications and Media Authority, PO Box 78, Belconnen, ACT, 2616. Applications for review of decisions can be made using the R051 - Application for review of Decision form, available on the ACMA website.

Important

An application for the ACMA to reconsider a decision to impose or vary licence conditions must be made to the ACMA within 28 days of the day on which you are informed of the decision. An application for reconsideration made after that time may not be accepted.

ACMA contact details

Customer Service Centre
PO Box 78
BELCONNEN ACT 2616

Telephone: 1300 850 115
Email: info@acma.gov.au

ACMA website: www.acma.gov.au

Certain information contained in this licence record will be disclosed in the Register of Radiocommunications Licences (RRL), established and maintained pursuant to Part 3.5 of the *Radiocommunications Act 1992*.

Advisory Notes applying to licence no.: 1988402/1

Conditions applicable to the operation of Paging System station(s) authorised under this licence can be found in the Radiocommunications Licence Conditions (Apparatus Licence) Determination and the Radiocommunications Licenc Conditions (Land Mobile Licence) Determination. Copies of these determinations are available from the ACMA and from the ACMA home page (www.acma.gov.au).

Technical characteristics

Below is a summary of the technical characteristics of the licensed service. Further technical details not displayed here may be found on the ACMA website.

Main Station Site **Station 1:**

Site details	
Site ID	401562
Site address	Robina Hospital, 2 Bayberry Lane, ROBINA QLD 4226
Co-ordinates (GDA94)	Latitude: -28.07081 Longitude: 153.3764

Transmitter details	
Assigned frequency	148.737500 MHz
Bandwidth	25.0000 kHz
Freq. assign. ID	0001007421
Transmitter power	100.00 W
EIRP	250.00 W
Emission designator	16K0F2D
Antenna details	
Antenna ID	13302
Antenna polarization	V - Vertical linear
Antenna azimuth	
Antenna height (m)	25
Antenna type	Dipole-D

Advisory Notes applying to Station 1

The paging transmitter authorised by this licence has been licensed on the condition that the licensee accepts any mutual interference that occurs between this and any other paging service licensed to them on the same frequency within 100km.

Special Conditions applying to Station 1

When the transmitter is coupled to an antenna the level of all discrete spurious components caused by the transmitter & measured at the connection to the antenna must not exceed -30 DBM. Broadband noise floor of the transmitter measured at the same point must not exceed -47 DBM in a 16 kHz bandwidth for frequency offsets greater than 300 kHz from the transmit frequency.

The level of power in the adjacent channel must not exceed -22dBm.